DLP240-24-1

TEST DATA IEC61000 SERIES

| DWG No. CA736-58-01 | | | |
|------------------------|-----------------|-----------|------------------------|
| QA APPD | APPD | CHK | DWG |
| T.Murayania 45un./3 | 30.May. 2003 | 14/May103 | Younglei 14/May/'03 |

INDEX

| | | PAGE |
|----|--|---------|
| 1. | Electrostatic Discharge Immunity Test (IEC61000-4-2) | R - 1 |
| 2. | Radiated Radio-Frequency Electromagnetic Field Immunity Test (IEC61000-4-3) | R-2 |
| 3. | Electrical Fast Transient / Burst Immunity Test (IEC61000-4-4) | . R - 3 |
| 4. | Surge Immunity Test (IEC61000-4-5) | . R - 4 |
| 5. | Conducted Disturbances Induced by Radio-Frequency Field Immunity Test (IEC61000-4-6) | R - 5 |
| 6. | Power Frequency Magnetic Field Immunity Test (IEC61000-4-8) | . R - 6 |
| 7. | Voltage Dips, Short Interruptions Immunity Test (IEC61000-4-11) | R - 7 |

^{*} Test results are typical data. Nevertheless the following results are considered to be actual capability data because all units have nearly the same characteristics.

1. Electrostatic Discharge Immunity Test (IEC61000-4-2)

MODEL : DLP240-24-1

(1) Equipment Used

Electro Static Discharge Simulator

: NSG435

(SCHAFFNER)

Discharge Resistance : 330Ω

Capacity

: 150pF

(2) Test Conditions

Input VoltageOutput Current

: 100, 230VAC : 0%, 100% Output VoltagePolarity

: Rated : + , -

Number of Tests

: 10 times

Discharge Interval

: >1 second

Ambient Temperture : 25°C


(3) Test Method and Device Test Point

Contact Discharge

: FG, Case Screw

Air Discharge

: Input and Output Terminal



(4) Acceptable Conditions

- 1. Output voltage regulation not to exceed $\pm 5\%$ of initial (before test) value during test.
- 2. Output voltage to be within regulation specification after the test.
- 3. Along with 1 and 2, no discharge of fire or smoke, as well as no output failure.

| Contact Discharge (kV) | DLP240-24-1 | Air Discharge (kV) | DLP240-24-1 |
|------------------------|-------------|-------------------------|-------------|
| 2 | PASS | 2 | PASS |
| 4 | PASS | 4 | PASS |
| | | 8 | PASS |

2. Radiated Radio-Frequency Electromagnetic Field Immunity Test (IEC61000-4-3)

MODEL : DLP240-24-1

(1) Equipment Used

TS5010 RADIATION IMMUNITY MEASUREMENT SYSTEM (TOYO CORPORATION) BILOG ANTENNA (CHASE)


(2) Test Conditions

Input Voltage : 100, 230VAC
 Output Current : 100%
 Electromagnetic Frequency : 80~1000MHZ
 Output Voltage : Rated
 Amplitude Modulated : 80%, 1kHz
 Ambient Temperature : 25°C

Distance : 2.4m
 Wave Angle : Horizontal and Vertical

Sweep Condition : 1.0% Step Up, 2.8 Seconds Hold
 Test Angle : Top/Bottom, Both Sides, Front/Back

(3) Test Method



(4) Acceptable Conditions

- 1. Output voltage regulation not to exceed $\pm 5\%$ of initial (before test) value during test.
- 2. Output voltage to be within regulation specification after the test.
- 3. Along with 1 and 2, no discharge of fire or smoke, as well as no output failure.

| Radiation Field Strength (V/m) | DLP240-24-1 |
|--------------------------------|-------------|
| 1 | PASS |
| 3 | PASS |
| 10 | PASS |

3. Electrical Fast Transient / Burst Immunity Test (IEC61000-4-4)

MODEL : DLP240-24-1

(1) Equipment Used

EFT/B Generator : FNS-100L (NOISEKEN)


: 3 times

(2) Test Conditions

· Number of tests

(3) Test Method and Device Test Point

Apply to (N,L,FG), (NL), (N), (L), (FG)



(4) Acceptable Conditions

- 1. Output voltage regulation not to exceed $\pm 5\%$ of initial (before test) value during test.
- 2. Output voltage to be within output voltage regulation specification after the test.
- 3. Along with 1 and 2, no discharge of fire or smoke, as well as no output failure.

| Test Voltage (kV) | Repetition Rate (kHz) | DLP240-24-1 |
|----------------------|-----------------------|-------------|
| 0.5 | 5 | PASS ' |
| 1.0 | 5 | PASS |
| 2.0 | 5 | PASS |

4. Surge Immunity Test (IEC 61000-4-5)

MODEL : DLP240-24-1

(1) **Equipment Used**

Surge Generator

: NSG651 (SCHAFFNER)

 2Ω

Coupling Impedance

: Common 12Ω

Coupling Capacitance : Common 9uF

Normal 18uF

(2) **Test Conditions**

Input Voltage

: 100, 230VAC

Normal

Output Voltage

: Rated

Output Current

: 0%, 100%

Number of Tests

: 5 times

Polarity

:+,-

Mode

: Common, Normal


Phase

: 0, 90 deg

Ambient Temperature : 25°C

Test Method and Device Test Point (3)

Apply to Common mode(N-FG, L-FG) and Normal mode(N-L)



Acceptable Conditions (4)

- 1. Output voltage regulation not to exceed $\pm 5\%$ of initial (before test) value during test.
- 2. Output voltage to be within regulation specification after the test.
- 3. Along with 1 and 2, no discharge of fire or smoke, as well as no output failure.

Test Result (5)

| Test Voltage (kV) Common | DLP240-24-1 | Test Voltage (kV) Normal | DLP240-24-1 |
|----------------------------|-------------|-----------------------------|-------------|
| 0.5 | PASS | 0.5 | PASS |
| 1.0 | PASS | 1.0 | PASS |
| 2.0 | PASS | 2.0 | PASS |
| 4.0 | PASS | | C |

5. Conducted Disturbances Induced by Radio-Frequency Field Immunity Test (IEC61000-4-6)

MODEL: DLP240-24-1

Equipment Used (1)

RF POWER AMPLIFIER

A01580-50-R (R&K)

SIGNAL GENERATOR

SMG (ROHDE & SCHWARZ)

COUPLING DE-COUPLING NETWORK (CDN)

KSI-8003 (KYORITSU)

(2) Test Conditions

Input Voltage

: 100, 230VAC

Output Voltage

: Rated

Output Current


: 100%

Electromagnetic Frequency : 150kHz~80MHz

 Sweep Condition • Ambient Temperature : 1.0% Step Up, 2.8 Seconds Hold

: 25°C

Test Method (3)



Acceptable Conditions (4)

- 1. Output voltage regulation not to exceed $\pm 5\%$ of initial (before test) value during test.
- 2. Output voltage to be within regulation specification after the test.
- 3. Along with 1 and 2, no discharge of fire or smoke, as well as no output failure.

| Voltage Level (V) | DLP240-24-1 | |
|-------------------|-------------|--|
| 1 | PASS | |
| 3 | PASS | |
| 10 | PASS | |

6. Power Frequency Magnetic Field Immunity Test (IEC61000-4-8)

MODEL : DLP240-24-1

(1) Equipment Used

AC Power Source : 1501L (California Instrument)

Signal Phase Power Analyzer : PM100 (Voltech)

Shunt Resister : 2.5Ω


Helmholts Coil : HHS5215 (Spulen)

(2) Test Conditions

Input Voltage : 100, 230VAC • Output Voltage : Rated
 Output Current : 100% • Magnetic Frequency : 50Hz
 Test Time : More than 10sec(Each direction) • Direction : X, Y, Z

Ambient Temperature : 25°C

(3) Test Method and Device Test Point



(4) Acceptable Conditions

- 1. Output voltage regulation not to exceed ±5% of initial (before test) value during test.
- 2. Output voltage to be within regulation specification after the test.
- 3. Along with 1 and 2, no discharge of fire or smoke, as well as no output failure.

| Magnetic Field Strength (A/m) | DLP240-24-1 | |
|-------------------------------|-------------|--|
| 1 | PASS | |
| 3 | PASS | |
| 10 | PASS | |
| 30 | PASS | |

7. Voltage Dips, Short Interruptions Immunity Test (IEC61000-4-11)

MODEL : DLP240-24-1

(1) Equipment Used

Test Generator


: 4420 (NF)

(2) Test Conditions

Input Voltage : 100, 230VAC
 Output Current : 100%
 Output Temperature : 25°C

Number of Tests : 3 times
 Test interval : More than 10sec

(3) Test Method and Device Test Point



(4) Acceptable Conditions

At Test level 70%

- 1. Output voltage regulation not to exceed $\pm 5\%$ of initial (before test) value during test.
- 2. Output voltage to be within output voltage regulation specification after the test.
- 3. Along with 1 and 2, no discharge of fire or smoke, as well as no output failure.

At Test level 40%, 0%

- 1. Output voltage to be within output voltage regulation specification after the test.
- 2. No discharge of fire or smoke.

| Test Level | Dip rate | Continue Time | DLP240-24-1 |
|------------|----------|---------------|-------------|
| 70% | 30% | 10ms | PASS |
| 40% | 60% | 100ms | PASS |
| 0% | 100% | 5000ms | PASS |